



**CITY OF BOSTON
FIRE DEPARTMENT
BDA Compliance Certification**



Installation Address: _____

Date: _____

Building Name: _____

Permit #: _____

Radio System Service Company: _____

BDA Manufacturer _____ **Model No.** _____ **FCC Certification** _____

***** RADIO TECHNICIAN CERTIFICATION *****

I hereby certify that the In-Building Radio System at the above address was installed and tested in accordance with the requirements of the BFD In-Building Radio Specification (Revision 14.1) and is in compliance with same.

Name: _____

FCC License #: _____

Employer: _____

Expiration Date: _____

Signature: _____

Date _____

***** MAINTENANCE CONTRACT CERTIFICATION *****

I hereby certify that a maintenance contract is in place for the In-Building Radio System at the above address. This agreement provides 24 hour by 7 day emergency response within two (2) hours after notification. The BFD Radio Supervisor shall be notified in writing at least thirty (30) days prior to cancellation of a maintenance contract. Such notice shall contain the date and time such cancellation is to take effect.

Service Provider: _____

Contract Expiration Date: _____

Name: _____

Title: _____

Signature: _____

Date _____

For office use only

	Acceptable	Comments
Location of strobe/horn		
Strobe/horn Function		
Sign Wording		
Cabinet Label		
Service Contract		
As Built Documentation		
Sample test		

Uplink Gain:	
Downlink Gain:	

The Sample Testing indicates an acceptable level of radio signal to provide effective firefighter communications.

Signature: _____

Date: _____

Title: _____